

2-23-14



# FCSOT

## HAZ MAT - INCIDENT WORKSHEET

**\*IDENTIFY \* ISOLATE \* MITIGATE \* TERMINATE\***

HAZARD	RESOURCES	MATERIAL DATA	
Wind Direction <i>WEST TO EAST</i>	EMA office 654-4357	Name	
Entry <i>J. Kramer</i>	Jon 438-5304/Christy 438-5096	<i>Propane</i>	
Decon <i>N/A</i>	Columbus Fire HM 4/Alarm Office 614 221-2345	I.D.#	
Haz Mat EMS <i>N/A</i>	Surrounding county Hazmat Teams	LEL	
Perimeter / Zones <i>N/A</i>	PUCO Hazmat hotline 800 642 3443	UEL	
Medical / Rehab <i>N/A</i>	EPA 1 800 282 9378	Specific Gravity	
Evacuation Location <i>N/A</i>	Chemtrec 1 800 424 9300	Vapor Density	
	Poison Control 1 800 222 1222	Readings	
Backup <i>E-561 crew</i>	Fairfield County Health Dept. 653-4489 24 hour pager 734 0205		
	Haz Mat Safety Officer <i>J Kramer</i>		ODH / Radiological 800-523-4439
	Scene Safety <i>Chief 560</i>		ODOT / Ohio Highway Patrol 653-1523
Research <i>N/A</i>	DOT Response Guide	<b>SUPPORT</b>	
Accountability <i>E-561 Pump Operator</i>	Law Enforcement	Staging	
	<b>OTHER INFO:</b>	Air Supply	
<b>WMD EVENT</b>		Rehab	
Law Enforcement		Red Cross	
52 <sup>nd</sup> WMD/CST 1-866-496-3278		Gas	
Bomb Squad / Secondary Devices		Electric	
Radiation Monitoring		Water	

### On Scene FCSOT Haz Mat personnel

UNIT	Assign	Unit	Assign	UNIT	Assign	Unit	Assign
<i>J. Kramer</i>	<i>to scene</i>	<i>T. Gung</i>	<i>To scene</i>	<i>J. Anspaugh</i>	<i>R-641</i>	<i>S. Feltz</i>	<i>to scene</i>

Dispatched to Greenfield Top on propane leak. 2-23-14

J. Kramer on scene spoke with CH 560 that they had a relief valve on a 500 gallon tank releasing propane. They already tried to contact a couple propane companies. Trinity Propane called back and was getting people lined up to respond to that location. The homeowner had called them. I spoke with a gentleman from Trinity and he advised me to try putting some hot water on valve and tapping it with a hammer. To try to reset seal on relief valve. I tried that and it didn't work. I called him back and advised him that I also sent him pictures of the relief valve. He told me he was still trying to get a team together. He also advised me that very little propane was being released. He has dealt with this same scenario before and didn't believe it was a high hazard. Myself and Chief Morris talked to home owner about calling Trinity propane back and find out how much this was going to cost him. I gave him the contact info and all Haz Mat persons cleared.

R-641 was cancelled onsite.

<b>UNIT</b>	<b>Assign 1</b>	<b>Assign 2</b>	<b>Assign 3</b>	<b>UNIT</b>	<b>Assign 1</b>	<b>Assign 2</b>	<b>Assign 3</b>

# HAZARDOUS MATERIALS CLASSIFICATION



## BUILDING PLACARD



